

City of Sumner
Dieringer Well Electrical Panel Procurement, CIP 21-02
Addendum #1



Date of Issue: August 3, 2021
Date of Opening: Unchanged (Wednesday, August 18th, 2021 at 11am)

Notice to All Plan holders:

This Addendum #1, containing the following revisions, additions, deletions and/or clarifications is hereby made part of the Plan and Contract Documents for the above-named project. Bidders shall take this Addendum into consideration when preparing and submitting their bids and it shall be attached to the Contract Documents.

Contractors shall acknowledge receipt of this Addendum #1 in the place provided on the Proposal –Signature Page. Failure to do so may disqualify the Bidder from consideration of its bid.

Modifications to the Plans


None

Modifications to the Specifications

None.

General Information

Drawing E2 (Sheet 2 of 3) Key Note 4 requires provision of a DV/DT Filter to match the existing motor. The name plate on the existing motor is shown at right.



ALL OTHER REQUIREMENTS OF THE CONTRACT DOCUMENTS REMAIN IN EFFECT.

Sincerely,

Jason Van Gilder
Associate City Engineer