

## Notice Of Application and Hearing

NOTICE IS HEREBY GIVEN that the City of Sumner Shoreline Administrator has received shoreline substantial development permit, shoreline conditional use and shoreline variance applications for improvements to the existing Waste Water Treatment Plant (WWTP). Additional details can be found below and with the project documents.

The public has the right to review the contents of the official file for the proposal, provide written comments, and request a copy of the final decision.

Comments may be emailed to the staff contact below, submitted or mailed to the attention of Scott Waller at 1104 Maple St. Sumner, WA 98390. Comments will be accepted if filed with the Development Services Department on or no later than August 18, 2025, additionally written or verbal testimony may be presented during the public hearing.

Project Name:	Waste Water Treatment Plant Biosolids Modernization
Permit Application	SSDP-2025-0003(Shoreline Substantial Permit), SSD-2025-0002
Numbers:	(Shoreline CUP) and SSD-2025-0004 (Shoreline Variance)
Location:	13114 63 <sup>rd</sup> Street East Sumner, WA 98390
Parcel(s) #:	4250001210, 4250001080 and 4250001220
Parcel(s) #: Description of Proposal:	<ul> <li>4250001210, 4250001080 and 4250001220</li> <li>Replace components of the existing Class A biosolids treatment system at the City's WWTP that are either capacity limited or reaching the end of their service life. Scope of work includes:</li> <li>Expansion of the existing Solids Handling Building to house the new biosolids drying equipment. The building expansion will be a single-story structure, equal in height to the existing Solids Handling Building.</li> <li>Demolition of the existing Sludge Haul Truck Loading Bay on the south side of the Solids Handling Building, along with the existing canopy/roof structure.</li> <li>Install the following new/replacement equipment in the Solids Handling Building and building expansion: New dewatered biosolids conveyors; A new dewatered biosolids cake pump to feed the new dryer; A new indirect biosolids dryer; Two new thermal fluid heaters each capable of utilizing either digester gas or natural gas along with</li> </ul>
	the associated thermal fluid pumping systems; Dried biosolids conveyance, cooling and screening systems; Replacement of the existing sludge storage hopper augers and drive motors; New waste
	activated sludge thickening system including a rotary screen
	thickener, sludge pumps, and polymer system; New in-line sludge grinders on the suction side of the digester recirculation pumps; New
	restroom; Odor control system modifications.

Applicant:	City of Sumner Michael Kosa
	the removal of vegetation.
	pine trees. Plant native trees and shrubs, at a 2:1 ratio, to mitigate for
	• Remove 18 ornamental shrubs, two fruit trees, one cedar tree and 3
	State Street. New paved area: approximately 1,180 sf.
	approximately the intersection of State Street and 63rdStreet E. Install a paved vehicle turn-around in the vicinity of the new gate on
	at the south end of State Street after the existing crosswalk, at
	to provide added security for the WWTP. The gate will be installed
	• Install a gate across State Street and fence the north parking lot area
	expansion.
	sf between the new generator and the Solids Handling Building
	approximately 670 sf north of the UV Disinfection Facility and 220
	• Pave currently pervious areas within the WWTP site including
	enclosure with sub-base fuel storage.
	generator will be housed in a stand-alone weatherproof acoustic
	Handling Building and to critical solids handling components. The
	portions of the liquid stream system that are powered from the Solids
	<ul> <li>Install a new diesel generator to provide standby power to the</li> </ul>
	Demolish existing diesel fuel storage tank.
	be repurposed into a new electrical room.
	Building Electrical Room or in the existing generator room that will
	control equipment will be installed in the existing Solids Handling
	for all modified and new treatment plant components. New motor
	<ul> <li>Install new power distribution, controls and instrumentation systems</li> </ul>
	drains, potable water, natural gas, digester gas, sludge, non-potable water and stormwater piping.
	• Install new/relocated/modified process and yard piping, including
	Puget Sound Clean Air Agency regulations.
	• New 4-inch enclosed waste gas burner that will meet all applicable
	and moisture removal.
	• New digester gas compressor and treatment system, including H2S
	and covers once the walls have been raised.
	feet and removal and reinstallation of the existing mechanism bridge
	• Raise the walls of the existing central holding tank an additional 6
	pumps with a new progressing cavity pump.
	• Replacement of the existing rotary lobe thickened primary sludge
	associated equipment in the Equipment Building 2.
	• Demolition of existing dissolved air floatation thickener and
	Solids Building Expansion and Loading Bay.
	Sludge Haul Truck Loading Bay and the construction of the new
	Haul Truck Loading Bay for use during the demolition of the existing
	Construction and subsequent demolition of a temporary Sludge
	and dust control systems.
	side of the new Solids Handling Building Expansion, including truck scales, automation of load distribution in the haul truck bed/container.
	side of the new Nolide Handling Building Evolution including truck

	1104 Maple Street, Ste 260 Sumner, WA 98390 Contact – Doug Welch, Gray and Osborne, Inc. 1130 Rainier Ave S, Seattle, WA 98144 206-283-3206 dwelch@g-o.com
Date of Application:	March 27, 2025
Date of Complete Application:	March 27, 2025
Hearing Date:	A public hearing is set for <b>Wednesday August 20<sup>th</sup> at 2:00pm</b> . This hearing will be <b>hybrid</b> , with access at Sumner City Hall's Council Chambers at 1105 Maple Street and virtual access in the link below.
Location/Zoom Link:	When: Aug 20, 2025 02:00 PM Pacific Time (US and Canada) Topic: Public Hearing Join from PC, Mac, iPad, or Android: <u>https://sumnerwa-gov.zoom.us/j/89066585432</u> Phone one-tap: +12532050468,,89066585432# US
Zoning:	Project takes place in the low density residential zone with a comprehensive plan designation of low density residential and public private utilities and facilities.
SEPA:	MDNS has been issued under SEPA-2025-0007
Other Required Permits:	<ul> <li>-Shoreline Substantial Development Permit</li> <li>-Shoreline Variance (required for improvements located within the 200 of Urban Conservancy Buffer for the Puyallup and White Rivers)</li> <li>-Shoreline Conditional Use Permit application (required for utility improvements in the Urban Conservancy Environment</li> <li>-Zoning Conditional Use Permit (required for upgrading the WWTP within the Low Density Residential Zone (LDR) per SMC 18.12.050(F)).</li> <li>-Habitat Management Plan (required per SMC 16.56.080 to assess potential project effects on fish and wildlife habitat)</li> <li>-Notice of Construction (NOC) Approval - Puget Sound Clean Air Agency.</li> <li>-Site development permit(s)</li> <li>-Compliance with all State and Federal regulations</li> </ul>
Associated Documents:	https://sumnerwa.gov/combined-noa-noa-ssd-2025-0003-ssd-2025- 0002-ssd-2025-0004/
Comment Period(s):	Any persons desiring to submit written comments concerning this application may submit written comments to Scott Waller of the Development Services Department. City of Sumner, 1104 Maple Street, Sumner, WA 98390 <b>no later than August 18, 2025</b> ,

	additionally written or verbal testimony may be presented during the public hearing.
Staff Contact:	For comments/questions, please contact Scott Waller, Senior Planner 253-299-5527, scottw@sumnerwa.gov
Published:	July 10 <sup>th</sup> , 2025
Posted/Mailed:	July 10 <sup>th</sup> , 2025